



NOTE: THIS IS AN EXAMPLE OF A RESIDUAL INSTALLATION OF A RPPA. THIS DETAIL APPLIES TO RESIDENTIAL AND COMMERCIAL APPLICATIONS WHERE THE RPPA DEVICE WILL BE LOCATED AWAY FROM THE RIGHT-OF-WAY/PROPERTY LINE (EXAMPLE SHOWN ABOVE). THE WATER LINE BETWEEN THE METER AND RPPA WILL BE REQUIRED TO BE ENCASED IN THE APPROPRIATE SIZE DIP OR STEEL ENCASEMENT PIPE WHEN THE RPPA IS INSTALLED AS SHOWN ABOVE.

CITY OF SALISBURY, N.C.	STANDARD DETAIL	DATE: FEBRUARY 6, 2007
STANDARD DETAIL TO LOCATE RPPA AT SIDE OF HOUSE/BUILDING		NOT TO SCALE
		STANDARD BF-14